



Entwicklungs- und Prüflabor
Holztechnologie GmbH
Zellescher Weg 24 · D-01217 Dresden
www.eph-dresden.de

Test laboratory accredited by Deutsche Akkreditierungsstelle GmbH (DAkkS)
(German Accreditation System of Testing) acc. to DIN EN ISO/IEC 17025




Deutsche
Akkreditierungsstelle
D-PL-11054-01-00

TEST CERTIFICATE


CT-13-01-16-02

- Product:** 3-layer solid wood board
Thickness: 60 mm
- Customer:** Nordpan AG/Spa
Zona Industriale 7
I – 39030 Olang/Valdaora (BZ)
- Order:** Determination and validation of the VOC and Formaldehyde emission according to the AgBB-Scheme (Committee for Health-related Evaluation of Building Products) and French Regulation "Arrêté étiquetage"
- Test method:** Test chamber method and analytics according to DIN EN ISO 16000 part 3, 6, and 9
- Test report:** 252391/1 dated 2013-01-08
- Test result:** The 3-layer solid wood board meets the requirements of the AgBB-Scheme. Furthermore it meets the requirements regarding French regulation "Arrêté étiquetage" Category A+.

Dresden, 2013-01-16


Head of laboratory




Engineer in charge